

**Product Evaluation Report**

**Report No.:** FL-41130.2

**Date:** July 1, 2023

Product Category	Sub Category	Manufacturer	Product Name
Exterior Doors	Swinging Exterior Door Assemblies	DKS Steel Door & Frame Systems, Inc. 2142 Tubeway Ave. Commerce, CA 90040 (323) 888-7763	DKS Series 1800 Steel Commercial Door Outswing "Impact"

**Scope:** This is a Product Evaluation report issued by R W Building Consultants, Inc. and Lyndon F. Schmidt, P.E. for DKS Steel Door & Frame Systems, Inc. based on Rule Chapter No. 61G20-3, Method 1D of the State of Florida Product Approval, Department of Business & Professional Regulation.

RW Building Consultants and Lyndon F. Schmidt, P.E. do not have nor will acquire financial interest in the company manufacturing or distributing the product or in any other entity involved in the approval process of the product named herein.

**Limitations:**

1. This product has been evaluated and is in compliance with the 8th Edition (2023) Florida Building Code (FBC) structural requirements including the "High Velocity Hurricane Zone" (HVHZ).
2. Product anchors shall be as listed and spaced as shown on details. Anchor embedment to base material shall be beyond wall dressing or stucco.
3. When used in the "HVHZ" this product complies with section 1626 of the Florida Building Code and does not require an impact resistant covering.
4. When used in areas outside of the "HVHZ" requiring wind borne debris protection this product complies with FBC Sections 1609.1.2 & R301.2.1.2 and does not require an impact resistant covering. This product meets missile level "D" and includes Wind Zone 4 as defined in ASTM E 1996 and FBC Sections 1609.1.2.2 & R301.2.1.2.1.
5. Site conditions that deviate from the details of drawing FL-41130.2 require further engineering analysis by a licensed engineer or registered architect.
6. This product does not meet the water infiltration requirements for the "HVHZ" and shall be installed only in non-habitable areas or at habitable locations protected by an overhang or canopy such that the angle between the edge of canopy or overhang to sill is less than 45 degrees.
7. When used in the "HVHZ", steel must be protected as specified in FBC Section 2222.6.
8. See drawing FL-41130.2 for size and design pressure limitations..

**Supporting Documents:**

- |   |   |  |  |
|---|---|--|--|
| 1. <b>Test Report No.</b><br>ATI 95951.01-201-18<br>TEL 01821092<br>ITS 3053378   | <b>Test Standard</b><br>TAS 201, 202 & 203-94<br>TAS 201, 202 & 203-94<br>UL 10C - 09 | <b>Testing Laboratory</b><br>Architectural Testing, Inc.<br>Testing Evaluation Lab., Inc.<br>Intertek Testing Services | <b>Signed by</b><br>Joseph A. Reed, P.E.<br>William Shelton, P.E.<br>Mike van Geyn |
| 2. <b>Drawing No.</b><br>No. FL-41130.2   | <b>Prepared by</b><br>RW Building Consultants, Inc. (#9813)                           | <b>Signed &amp; Sealed by</b><br>Lyndon F. Schmidt, P.E.   |  |
| 3. <b>Calculations</b><br>Anchoring   | <b>Prepared by</b><br>RW Building Consultants, Inc. (#9813)                           | <b>Signed &amp; Sealed by</b><br>Lyndon F. Schmidt, P.E.   |  |
| 4. <b>Quality Assurance</b><br>Certificate of Participation issued by National Accreditation and Management Institute, certifying that DKS Steel Door & Frame Systems, Inc. is manufacturing products within a quality assurance program that complies with ISO/IEC 17020 and Guide 53. |   |  |  |

LYNDON F. SCHMIDT, State of Florida, Professional Engineer, License No. 43409  
This item has been digitally signed and sealed by L. F. Schmidt on 7-19-23.  
Printed copies of this document are not considered signed and sealed and the signature must be verified on any electronic copies.  
**THIS PRODUCT APPROVAL IS VALID ONLY FOR THE STATE OF FLORIDA**